

1.3.9 Aggregate Commercial Building Component Loads (1)

Component	Loads (quads) and Percent of Total Loads			
	Heating		Cooling	
Roof	-0.103	12%	0.014	1%
Walls (2)	-0.174	21%	-0.008	-
Foundation	-0.093	11%	-0.058	-
Infiltration	-0.152	18%	-0.041	-
Ventilation	-0.129	15%	-0.045	-
Windows (conduction)	-0.188	22%	-0.085	-
Windows (solar gain)	0.114	-	0.386	32%
Internal Gains				
Lights	0.196	-	0.505	42%
Equipment (electrical)	0.048	-	0.207	17%
Equip. (non-electrical)	0.001	-	0.006	1%
People	0.038	-	0.082	7%
NET Load	-0.442	100%	0.963	100%

Note(s): 1) "Loads" represents the thermal energy losses/gains that, when combined, will be offset by a building's heating/cooling system to maintain a set interior temperature (which then equals *site* energy). 2) Includes common interior walls between buildings.

Source(s): LBNL, Commercial Heating and Cooling Loads Component Analysis, June 1998, Table 24, p. 45 and Figure 3, p. 61.